

**BUILDING TRUST** 

# PRODUCT DATA SHEET Sikasil<sup>®</sup>-403 Fire

# Fire-rated silicone joint sealant

# DESCRIPTION

Sikasil®-403 Fire is a fire rated, silicone based, 1-component, UV-stable, moisture-curing, low-modulus elastic joint sealant.

Suitable for use in hot and tropical climatic conditions.

# USES

Sikasil<sup>®</sup>-403 Fire is designed for fire rated movement and connection joints on porous and non-porous substrates. It is also suited for use as a weather sealant for movement and connection joints in building envelopes.

# FEATURES

- Up to 4 hours fire resistance according to EN 1366-4
- Fire resistance tests passed according to EN 1363-1
- Particularly good resistance to weathering
- Movement capability of ± 50 % (ASTM C 719)
- Good adhesion to various substrates
- Neutral curing
- Low VOC

# SUSTAINABILITY

 Certified according to "Low Emitting Materials as per Al Sa'fat - Dubai Green Building Evaluation System" by Dubai Central Laboratory (DCL)

# **CERTIFICATES AND TEST REPORTS**

- Tested acc. EN 1366-4:2006
- Tested acc. EN 1363-1:2020
- Tested acc. ASTM C920 (class 50)
- VOC test report (US EPA Method 24)
- VOC Emission Test Report (CDPH)

# **PRODUCT INFORMATION**

Composition	Neutral cure silicone 600 ml foil pack, 20 foil packs per box 300 ml cartridge, 12 cartridges per box		
Packaging			
Colour	White, grey, concrete grey, black (other colors on request)		
Shelf life	Sikasil <sup>®</sup> -403 Fire has a shelf life of 12 months from the date of produc if it is stored in undamaged, original, sealed packaging, and if the stor conditions are met.		
torage conditions Sikasil <sup>®</sup> -403 Fire shall be stored in dry conditions, where it is p from direct sunlight and at temperatures between +5 °C and +			
Density	~1.22 kg/l		

Product Data Sheet Sikasil®-403 Fire February 2025, Version 02.01 020517010030000005

# **TECHNICAL INFORMATION**

Shore A hardness	~30 (28 d)			
Tensile strength	~0.7 MPa		(CQP036-1 / ISO 527)	
Movement capability	±50 %		(ASTM C 719)	
Service temperature	–40 °C to 150 °C max.			
Joint design	The joint width must be designed to suit the joint movement required an- dthe movement capability of the sealant. The joint width shall be $\geq$ 10 mm and $\leq$ 45 mm. The joint depth shall be $\leq$ 15 mm. A width to depth ratio of 2 : 1 must be maintained (for exceptions, see ta- ble below). Standard joint widths for joints between concrete elements: (Movement Capability: ±50 % (ASTM C719) and $\Delta$ T: 80 °C)			
	Joint distance [m]	Min. joint width [mm]		
	2	$-\frac{10}{12}$	<u>10</u>	
	4	<u>12</u>	10	
	6		10	
	8	22		
	10	28	14	
	For larger joints following depth should be maintained:			
	Joint width [mm]	Joint dep		
	30	<u>15</u>		
	35	18		
		10		
	40 45 All joints must be corre the relevant standards	20 20 ectly designed and dimer s before their constructio	nsioned in accordance with n. The basis for calculation	
	40 45 All joints must be correct the relevant standards of the necessary joint the technical values of material, as well as the	20 20 ectly designed and dimer before their constructio widths are the type of str the adjacent building ma e specific exposure of the	n. The basis for calculation ructure and its dimensions, aterials and the joint sealing building and the joints. For	
Elongation at break	40 45 All joints must be correct the relevant standards of the necessary joint the technical values of material, as well as the more detailed advice a	20 20 ectly designed and dimer before their constructio widths are the type of str the adjacent building ma e specific exposure of the	n. The basis for calculation	
Elongation at break Consumption	40 45 All joints must be correction the relevant standards of the necessary joint the technical values of material, as well as the more detailed advice a ment.	20 20 ectly designed and dimer before their constructio widths are the type of str the adjacent building ma e specific exposure of the	n. The basis for calculation ructure and its dimensions, aterials and the joint sealing building and the joints. For ontact our Technical Depart-	
	40 45 All joints must be correct the relevant standards of the necessary joint with the technical values of material, as well as the more detailed advice a ment. ~470 % Joint length [m]	20   20   20   20   ectly designed and dimer   5 before their constructio   widths are the type of str   The adjacent building mage   e specific exposure of the   and instructions please co   Joint width [mm]   10	n. The basis for calculation ructure and its dimensions, aterials and the joint sealing e building and the joints. For ontact our Technical Depart- (CQP036-1 / ISO 527) Joint depth [mm] 10	
	40 45 All joints must be correction the relevant standards of the necessary joint with the technical values of material, as well as the more detailed advice a ment. ~470 % Joint length [m] per 600 mL foil pack	20   20   20   20   ectly designed and dimer   5 before their constructio   widths are the type of str   The adjacent building mage   e specific exposure of the   and instructions please co   Joint width [mm]   10   15	n. The basis for calculation ructure and its dimensions, aterials and the joint sealing e building and the joints. For ontact our Technical Depart- (CQP036-1 / ISO 527) Joint depth [mm] 10 10	
	40 45 All joints must be correction the relevant standards of the necessary joint of the technical values of the technical values of the technical values of the technical values of the technical advice a more detailed advice a ment. ~470 % Joint length [m] per 600 mL foil pack 6 4 3	20   20   20   20   20   ectly designed and dimer   s before their constructio   widths are the type of str   the adjacent building mage   e specific exposure of the   and instructions please complete   Joint width [mm]   10   15   20	n. The basis for calculation ructure and its dimensions, aterials and the joint sealing building and the joints. For pontact our Technical Depart- (CQP036-1 / ISO 527) Joint depth [mm] 10 10 10	
	40 45 All joints must be correction the relevant standards of the necessary joint of the technical values of technical valu	20   20   20   20   20   ectly designed and dimer   s before their constructio   widths are the type of str   the adjacent building mage   e specific exposure of the   and instructions please condition   Joint width [mm]   10   15   20   25	n. The basis for calculation ructure and its dimensions, aterials and the joint sealing building and the joints. For ontact our Technical Depart- (CQP036-1 / ISO 527) Joint depth [mm] 10 10 12	
	40 45 All joints must be correction the relevant standards of the necessary joint of the technical values of te	20   20   20   20   20   ectly designed and dimer   s before their constructio   widths are the type of str   The adjacent building mage   e specific exposure of the   and instructions please condition   Joint width [mm]   10   15   20   25   30	n. The basis for calculation ructure and its dimensions, aterials and the joint sealing e building and the joints. For pontact our Technical Depart- (CQP036-1 / ISO 527) Joint depth [mm] 10 10 12 15	
	40 45 All joints must be correction the relevant standards of the necessary joint of the technical values of te	20   20   20   20   20   20   20   ectly designed and dimer   5 before their constructio   widths are the type of str   The adjacent building mage   e specific exposure of the   and instructions please co   Joint width [mm]   10   15   20   25   30   35	n. The basis for calculation ructure and its dimensions, aterials and the joint sealing e building and the joints. For portact our Technical Depart- (CQP036-1 / ISO 527) Joint depth [mm] 10 10 10 12 15 15	
	40 45 All joints must be correction the relevant standards of the necessary joint with the technical values of material, as well as the more detailed advice a ment. ~470 % Joint length [m] per 600 mL foil pack 6 4 3 2 1.3 1 0.8	20   20   20   20   20   20   20   ectly designed and dimer   5 before their constructio   widths are the type of str   5 the adjacent building mage   e specific exposure of the   and instructions please co   Joint width [mm]   10   15   20   25   30   35   40	n. The basis for calculation ructure and its dimensions, aterials and the joint sealing e building and the joints. For portact our Technical Depart- (CQP036-1 / ISO 527) Joint depth [mm] 10 10 10 12 15 15 15	
	40 45 All joints must be correction the relevant standards of the necessary joint of the technical values of te	20   20   20   20   20   20   20   ectly designed and dimer   5 before their constructio   widths are the type of str   The adjacent building mage   e specific exposure of the   and instructions please co   Joint width [mm]   10   15   20   25   30   35	n. The basis for calculation ructure and its dimensions, aterials and the joint sealing e building and the joints. For portact our Technical Depart- (CQP036-1 / ISO 527) Joint depth [mm] 10 10 10 12 15 15	
Consumption	40 45 All joints must be correction the relevant standards of the necessary joint with the technical values of material, as well as the more detailed advice a ment. ~470 % Joint length [m] per 600 mL foil pack 6 4 3 2 1.3 1 0.8 0.7	20   20   20   20   20   20   20   ectly designed and dimer   5 before their constructio   widths are the type of str   5 the adjacent building mage   e specific exposure of the   and instructions please co   Joint width [mm]   10   15   20   25   30   35   40	n. The basis for calculation ructure and its dimensions, aterials and the joint sealing e building and the joints. For ontact our Technical Depart- (CQP036-1 / ISO 527) Joint depth [mm] 10 10 10 10 12 15 15 15 15	
	40 45 All joints must be correction the relevant standards of the necessary joint with the technical values of material, as well as the more detailed advice a ment. ~470 % Joint length [m] per 600 mL foil pack 6 4 3 2 1.3 1 0.8 0.7 Use closed cell, polyet	20   20   20   20   20   20   ectly designed and dimer   5 before their constructio   widths are the type of str   The adjacent building mage   e specific exposure of the   and instructions please component   Joint width [mm]   10   15   20   25   30   35   40   45	n. The basis for calculation ructure and its dimensions, aterials and the joint sealing e building and the joints. For portact our Technical Depart- (CQP036-1 / ISO 527) Joint depth [mm] 10 10 10 12 15 15 15 15 15 5.	
Consumption Backing material	40 45 All joints must be correction the relevant standards of the necessary joint with the technical values of material, as well as the more detailed advice a ment. ~470 % Joint length [m] per 600 mL foil pack 6 4 3 2 1.3 1 0.8 0.7 Use closed cell, polyet	20   20   20   20   20   20   20   20   20   widths are their constructions widths are the type of stress of the adjacent building material specific exposure of the and instructions please constructions please constructions please constructions please constructions   Joint width [mm]   10   15   20   25   30   35   40   45   hylene foam backing rodi	n. The basis for calculation ructure and its dimensions, aterials and the joint sealing e building and the joints. For portact our Technical Depart- (CQP036-1 / ISO 527) Joint depth [mm] 10 10 10 12 15 15 15 15 15 5.	
Consumption Backing material Ambient air temperature	40 45 All joints must be correction the relevant standards of the necessary joint of the technical values of material, as well as the more detailed advice a ment. ~470 % Joint length [m] per 600 mL foil pack 6 4 3 2 1.3 1 0.8 0.7 Use closed cell, polyettion to the second se	20   20   20   20   20   20   ectly designed and dimer   5 before their constructio   widths are the type of str   The adjacent building mage   e specific exposure of the   and instructions please component   Joint width [mm]   10   15   20   25   30   35   40   45   hylene foam backing rod:   (min. 3 °C above dew point)	n. The basis for calculation ructure and its dimensions, aterials and the joint sealing e building and the joints. For portact our Technical Depart- (CQP036-1 / ISO 527) Joint depth [mm] 10 10 10 12 15 15 15 15 15 5.	

Product Data Sheet Sikasil®-403 Fire February 2025, Version 02.01 020517010030000005



**BUILDING TRUST** 

# **BASIS OF PRODUCT DATA**

All technical data stated in this Data Sheet are based on laboratory tests. Actual measured data may vary due to circumstances beyond our control.

# IMPORTANT CONSIDERATIONS

- Sikasil<sup>®</sup>-403 Fire cannot be overpainted.
- Do not use Sikasil<sup>®</sup>-403 Fire on natural stone.
- Do not use Sikasil<sup>®</sup>-403 Fire on bituminous substrates, natural rubber or on any building materials which might bleed oils, plasticizers or solvents that could attack the sealant. EPDM rubber needs to be tested for compatibility and approved by Sika Technical Department.
- Do not use Sikasil<sup>®</sup>-403 Fire to seal joints in and around swimming pools.
- Do not use Sikasile-403 Fire for joints under water pressure or for permanent water immersion.
- Colour variations may occur due to exposure to chemicals, high temperatures and/or UV-radiation (especially with the colour shade white). However, a change in colour is purely an aesthetic nature and does not adversely influence the technical performance or durability of the product.
- Do not expose uncured Sikasil<sup>®</sup>-403 Fire to alcohol containing products as this may interfere with the curing reaction.

# ECOLOGY, HEALTH AND SAFETY

For information and advice on the safe handling, storage and disposal of chemical products, users shall refer to the most recent Safety Data Sheet (SDS) containing physical, ecological, toxicological and other safety-related data.

# APPLICATION INSTRUCTIONS

# SUBSTRATE PREPARATION

The substrate must be clean, dry, sound and homogeneous, free from oils, grease, dust and loose or friable particles. The following priming and/or pre-treatment procedures shall be followed: Non-porous substrates

Anodised aluminium and stainless steel have to be pre-treated using Sika® Aktivator-205, Sika® Aktivator-100 or Sika® Cleaner P. Powder coated and PVDF coated metals have to be pre-treated using Sika® Aktivator-205. For details like application and flash-off times refer to the most recent Product Data Sheet of the respective pre-treatment product.

### Porous substrates

Concrete, aerated concrete and cement-based renders, mortars and bricks shall be primed using Sika® Primer-3 N or Sika® Primer-210. For details like application and flash-off times refer to the most recent Product Data Sheet of the respective pre-treatment product.

Adhesion tests on project specific substrates must be performed prior to application. For more detailed advice and instructions please contact our Technical Department.

Note: Primers are adhesion promoters. They are neither a substitute for the correct cleaning of a surface,

nor do they improve the strength of the surface significantly.

# APPLICATION METHOD / TOOLS

Sikasil<sup>®</sup>-403 Fire is supplied ready to use. After the necessary substrate preparation, insert a suitable backing rod to the required depth and apply any primer if necessary. Insert a foil pack or cartridge into the sealant gun and extrude Sikasil<sup>®</sup>-403 Fire into the joint making sure that it comes into full contact with the sides of the joint and avoids any air entrapment. Sikasil<sup>®</sup>-403 Fire sealant must be firmly tooled against the joint sides to ensure adequate adhesion. It is recommended to use masking tape where exact joint lines or neat lines are required. Remove the tape within the skin time. Do not use tooling products containing solvents.

# CLEANING OF EQUIPMENT

Clean all tools and application equipment immediately after use with Sika® Remover-208. Once cured, residual material can only be removed mechanically.

**BUILDING TRUST** 

Product Data Sheet Sikasil®-403 Fire February 2025, Version 02.01 020517010030000005



# LOCAL RESTRICTIONS

Note that as a result of specific local regulations the declared data and recommended uses for this product may vary from country to country. Consult the local Product Data Sheet for exact product data and uses.

# **LEGAL NOTES**

The information, and, in particular, the recommendations relating to the application and end-use of Sika products, are given in good faith based on Sika's current knowledge and experience of the products when properly stored, handled and applied under normal conditions in accordance with Sika's recommendations. In practice, the differences in materials, substrates and actual site conditions are such that no warranty in respect of merchantability or of fitness for a particular purpose, nor any liability arising out of any legal relationship whatsoever, can be inferred either from this information, or from any written recommendations, or from any other advice offered. The user of the product must test the product's suitability for the intended application and purpose. Sika reserves the right to change the properties of its products. The proprietary rights of third parties must be observed. All orders are accepted subject to our current terms of sale and delivery. Users must always refer to the most recent issue of the local Product Data Sheet for the product concerned, copies of which will be supplied on request.

#### Sika Gulf B.S.C. (c)

Tel: +973 177 38188 Email: info@bh.sika.com Sika Kuwait Cons. Mat. & Paints Co WLL Tel: +965 22 282 296 Email: sika.kuwait@kw.sika.com Web: gcc.sika.com



Product Data Sheet



#### Sika UAE LLC

Sika MB Construction Chemicals LLC Sika International Chemicals LLC Tel: +971 4 439 8200 Email: info@ae.sika.com Web: gcc.sika.com



#### Sika Saudi Arabia Limited

Sika Construction Chemicals for Manufacturing LLC Riyadh / Jeddah / Dammam / Rabigh Tel: +966 9200 22167 Email: info@sa.sika.com Web: gcc.sika.com

BUILDING TRUST

#### Sika LLC - Oman Sika MB LLC Tel. +968 22 826 500 Email: info@om.sika.com Web: gcc.sika.com

Sikasil-403Fire-en-AE-(02-2025)-2-1.pdf



**Sikasil®-403 Fire** February 2025, Version 02.01 020517010030000005